



Certificate of constancy of performance
according to AVCP-System 1

MPA Eberswalde

Materialprüfanstalt
Brandenburg GmbH

0763-CPR-6028

Prüfung, Überwachung,
Zertifizierung, Gutachten,
Forschung und Entwicklung

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) this certificate applies to the construction product

Alfred-Möller-Straße 1, H 13
D-16225 Eberswalde

Fon +49 (0) 33 34. 65 560
Fax +49 (0) 33 34. 65 550

www.mpaew.de
office@mpaew.de

Geschäftsführer:
Dr. Robby Wegner

HRB 10408 FF

Plywood Eko Fire Pine

according to EN 636 for use as structural components in humid
conditions for use as walls and roofs,
technical class EN 636-2 S, uncoated,
wood species: pine, nominal thickness ≥ 12 mm,
density $630 \text{ kg/m}^3 - 710 \text{ kg/m}^3$,
class of reaction to fire acc. to EN 13501-1: B – s1, d0.

This classification is valid for the following end use conditions acc. to
classification report SL/Z-280/EN 13501/0238/2024 of 05.04.2024.
mechanically fastened to wooden slats, with vertical and/or horizontal
joints, ventilated or unventilated air gap

produced by

Sklejka - Eko S.A.

ul. Reymonta 35, PL – 64-300 Ostrow Wlp.

and produced in the manufacturing plant

Sklejka - Eko S.A.

ul. Reymonta 35, PL – 64-300 Ostrow Wlp.

This certificate attests that all provisions concerning the assessment and
verification of constancy of performance described in Annex ZA of the standard

EN 13986:2004+A1:2015

under system 1 for the performances set out in this certificate are applied and that
the construction product fulfils all the prescribed requirements for these
performances.

This certificate was first issued on 06.05.2024 and will remain valid as long as the
test methods and/or factory production control requirements included in the
harmonised standard, used to assess the performance of the declared essential
characteristics, do not change, and the construction product, and the manufacturing
conditions in the plant are not modified significantly.

Eberswalde, 06.05.2024




Dr. Robby Wegner
Head of Certification Body

Sparkasse Schwandorf
Kto-Nr.: 100 164 862
BLZ: 750 510 40
IBAN: DE55 7505 1040 0100 1648 62
BIC-/SWIFT: BYLADEM1SAD
USt.-Id. DE814335485
Finanzamt Eberswalde



Die Akkreditierung gilt nur für die in der Urkunde aufgeführten Verfahren.



vom DIBt anerkannte
PÜZ-Stelle BRA02



EC notified 0763



CARB notified TPC 18