



Certificate of constancy of performance
according to AVCP-System 1

MPA Eberswalde

Materialprüfanstalt
Brandenburg GmbH

0763-CPR-6193

Prüfung, Überwachung,
Zertifizierung, Gutachten,
Forschung und Entwicklung

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) this certificate applies to the construction product

Alfred-Möller-Straße 1, H 13
D-16225 Eberswalde

Fon +49 (0) 33 34. 65 560
Fax +49 (0) 33 34. 65 550

www.mpaew.de
office@mpaew.de

Geschäftsführer:
Dr. Robby Wegner

HRB 10408 FF

EKO FIRE BIRCH

Plywood according to EN 636 for use as structural components (walls and ceiling), birch veneers, thickness ≥ 12 mm, uncoated, quality of bonding acc. to EN 314-2: class 3, class of reaction to fire acc. to EN 13501-1: B – s1, d0.

This classification is valid for the following end use conditions acc. to classification report SL/Z-078/EN13501/157/2019 of 03.04.2019.

Substrates:

Any substrate of euro classes A1 or A2 with or without an air gap.

produced by

SKLEJKA – EKO S.A.

ul. Reymonta 35, PL –63-400 Ostrów Wielkopolski

and produced in the manufacturing plant

SKLEJKA – EKO S.A.

ul. Reymonta 35, PL –63-400 Ostrów Wielkopolski

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard


EN 13986:2004+A1:2015

under system 1 for the performances set out in this certificate are applied and that the construction product fulfils all the prescribed requirements for these performances.

This certificate hereby replaces the certificate 0763-CPR-6026, dated 03.04.2019, and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product and the manufacturing conditions in the plant are not modified significantly.

Eberswalde, 11.02.2025




Dr. Robby Wegner
Head of Certification Body

Sparkasse Schwandorf
Kto-Nr.: 100 164 862
BLZ: 750 510 40
IBAN: DE55 7505 1040 0100 1648 62
BIC-/SWIFT: BYLADEM1SAD
USt.-Id. DE814335485
Finanzamt Eberswalde



Die Akkreditierung gilt nur für die in der Urkunde aufgeführten Verfahren.



vom DIBt anerkannte
PUZ-Stelle BRA02



EC notified 0763



CARB notified TPC 18